



CERTIFICATE

16 49 02

Document cabinets

Holder/Issued to/Manufacturer

Diplomat Safe Ltd, 19 NoksanSandan 261 Ro 60Gil, Gangseo-gu, Busan 618-818, Korea

Product

Document cabinets.

Product name

For details, see appendix.

Product information

See appendix.

Fire resistance class

NT FIRE 017 – 90 Paper

Performance specification

NT FIRE 017 and SP's certification rules for fire resisting storage cabinets, SPCR 002.

Marking

Marking in the cabinet shall show the name of the product, its fire resistance class, its serial number, the number of this certificate and SP's P-symbol.

Validity

This certificate is valid until not later than 30th September 2019.

Miscellaneous

The manufacturer's in-house inspection is under surveillance by SP in accordance with section 4 and 5 of SPCR 002. Other terms and conditions are set out in section 6 of SPCR 002. The certificate was originally issued on 23rd September 1999.

SP Technical Research Institute of Sweden
Certification



Lennart Aronsson
Product Certification Manager



Martin Tillander
Certification Officer



Certificate no. 16 49 02, issue 12, 1st March 2017

SP Technical Research Institute of Sweden

Box 857, SE-501 15 Borås, Sweden

Phone: +46 10-516 50 00

E-mail/internet: info@sp.se/www.sp.se

Swedish accredited certification bodies are appointed by SWEDAC, the Swedish Board for Accreditation and Conformity Assessment, under the terms of the Act. This certificate may not be reproduced other than in full, except with the prior written approval by SP. The certificate including appendix consists of 2 pages, where this is page 1.



CERTIFICATE

Appendix

Product information

Models covered by the certificate

Cabinet model	External dimensions (mm)			Internal dimensions (mm)			Weight (kg)
	width	height	depth	width	height	depth	
060	470	600	470	350	480	300	80
070	500	635	500	380	515	330	90
080	520	816	520	380	676	330	122

List of related product names

Cabinet model (see table 1)	Cabinet designation			
	Diplomat SAFE LTD	Skånska Byggvaror AB	Phoenix SAFE	Yale
060	060 SS060	diplomat 60G diplomat 600B Royal 60 RDL160	DS2002	
070	070 SS070 S700/DBAUM700	diplomat NGS150 diplomat 65G diplomat 650B diplomat EDL 150 Royal 65	DS2501E FS0441E	YFM-695-FG2
080	080 SS080 DBAUM800	diplomat NGS180 diplomat 80G diplomat 800B diplomat EDL 180 Royal 80 RDL180	DS2502E FS0442E	

Certificate no. 16 49 02, issue 12, 1st March 2017

SP Technical Research Institute of Sweden

Box 857, SE-501 15 Borås, Sweden

Phone: +46 10-516 50 00

E-mail/internet: info@sp.se/www.sp.se



Swedish accredited certification bodies are appointed by SWEDAC, the Swedish Board for Accreditation and Conformity Assessment, under the terms of the Act. This certificate may not be reproduced other than in full, except with the prior written approval by SP. The certificate including appendix consists of 2 pages, where this is page 2.